

A. TABLET METHOD Calcium hypochlorite tablets shall be installed in each length of pipe to insure a sufficient dosage of 50 ppm based on the following table:

Pipe Diameter	Tablets per Length
6"	2 ea. -5 gram tablets
8"	4 ea. -5 gram tablets
10"	6 ea. -5 gram tablets
12"	8 ea. -5 gram tablets
16"	14 ea. -5gram tablets

The tablets shall be attached by a food-grade adhesive such as Permatex No. 2 or Permatex Clear RTV Silicone Adhesive Sealant. Tablets shall be attached inside and at the top of the main with approximately equal numbers of tablets at each end of the pipe. Tablets must be water soluble.

B. LIQUID CHLORINE METHOD. Disinfection may be done by the addition of suitable amounts of chlorine in the form of liquid sodium hypochlorite as per AWWA B300 to obtain the results as the previous method described. Note: Permission for this method of disinfection shall be obtained by the District prior to construction.

3.22 PRESSURE TESTING Pressure Testing must be in accordance with AWWA Standards C600. The water main being tested shall have all air expelled by additional flushing or the installation of taps on high points in the line. The pressure of the water main shall be gradually increased to obtain a minimum pressure of 100 psi over the design pressure (250 psi minimum) at the lowest elevation point of the water main or as directed by the District. The test will be for a two (2) hour duration and will not vary by more than 5 psi. All tests performed for each test section shall be witnessed and approved by a representative of the District, in the event any test is performed without a representative of the District, the Contractor shall be required to test the section again. Leakage is defined as the amount of water used to maintain the test pressure.

REVISION	BY DATE	

N. KY. WATER DISTRICT
SPECIFICATIONS

DRAWN BY:
SAR

APPROVED:
RH

DATE:
2/02/11

STANDARD
DRAWING NO:
100-G