



DRAWING NOTES

- ① PIPING CLASS 52 WITH FLANGED END WITHIN PIT.
- ② VALVES WITH OUTSIDE SCREW AND YOKE, FLANGED CONNECTIONS. (RESILENT SEATED VALVES)
- ③ 2.5" OR LARGER COMPOUND METER
- ④ FLANGED COUPLING ADAPTER OVER PLAIN END PIPE FLANGED BY PLAIN END PIPE.
- ⑤ STRAINER
- ⑥ BYPASS LINE SHALL BE EQUALIVANT IN SIZE AS THE FEED LINE OR THE NEXT SIZE SMALLER (3" MINIMUM SIZE)
- ⑦ IF A PRESSURE REGULATOR IS REQUIRED IT SHALL BE INSTALLED AS SHOWN (DWG NO. 201 item No. 1.09)
- ⑧ SHADED AREA DISTRICTS RESPONSIBILITY

GENERAL NOTES

- 1. SEE DRAWING 202 FOR PIT CONSTRUCTION DETAILS.
- 2. SEE DRAWING 201 FOR PIT MATERIALS SPECIFICATIONS.
- 3. SEE DRAWING 203 FOR PIPING SPECIFICATIONS.
- 4. A BACKFLOW PREVENTION ASSEMBLY SHALL BE INSTALLED AS FIRST DEVICE INSIDE OF THE BUILDING. THERE SHALL BE NO BRANCHES OR TAPS BETWEEN THE METERING ASSEMBLY AND THE BACKFLOW PREVENTION ASSEMBLY.

REVISION	BY	DATE
COMPOUND METER ETC.	MPA	10/29/09
NOTE 4-GEN. NOTE	MPA	2/6/02

N. KY. WATER DISTRICT METER SETTINGS 2.5" AND LARGER	DRAWN BY:	SAR
	APPROVED:	<i>RH</i>
DATE:	2/02/11	
STANDARD DRAWING NO:	205R	