



NOTE: STRAINER, METER & DETECTOR CHECK VALVE SHALL BE U.L. LISTED ASSEMBLY PURCHASED FROM N. KY WATER DISTRICT.

DRAWING NOTES

- ① VALVES WITH OUTSIDE STEM AND YOKE, FLANGED CONNECTION (RESILIENT SEATED VALVES)
 - ② U.L. FIRE RATED STRAINER
 - ③ METER
 - ④ U.L. LISTED DETECTOR CHECK
 - ⑤ SPOOL PIECE, 12", FLANGED & PLAIN END
 - ⑥ GATE VALVE
 - ⑦ LOW FLOW METER
 - ⑧ CHECK VALVE
 - ⑨ BYPASS LINE SHALL BE EQUALIVANT IN SIZE AS THE FEED LINE OR THE NEXT SIZE SMALLER (3" MINIMUM SIZE)
 - ⑩ CLASS 52 PIPING WITH FLANGED END WITHIN PIT.
 - ⑪ PRESSURE REDUCING VALVE TO BE LOCATED BEFORE THE METER WHEN REQUIRED BY THE DISTRICT AND AFTER THE METER WHEN REQUIRED BY THE CUSTOMER
 - ⑫ SHADED AREA DISTRICTS RESPONSIBILITY
1. ANY PUMPER CONNECTION SHALL BE INSTALLED DOWN STREAM OF OUTLET VALVE & BACKFLOW DEVICE
 2. ANY POST INDICATOR SHALL BE THE TYPE THAT WILL ATTACH TO THE WHEEL OPERATOR AND ALLOW OPERATION OF VALVE WITHIN THE PIT.
 3. SEE DRAWINGS 202,201 & 203
 4. A BACKFLOW PREVENTION ASSEMBLY SHALL BE INSTALLED AS FIRST DEVICE INSIDE OF THE BUILDING. THERE SHALL BE NOT BRANCHES OR TAPS BETWEEN THE METERING ASSEMBLY AND THE BACKFLOW PREVENTION ASSEMBLY.

REVISION	DATE

N. KY. WATER DISTRICT FIRE RATED METER SETTING 4" & LARGER FOR PROPERTIES WITH PRIVATE FIRE & DOMESTIC WATER SERVICE	DRAWN BY: SAR
	APPROVED: <i>RH</i>
DATE:	2/17/10
STANDARD DRAWING NO:	208